# UniStream® Built-in

Installation Guide: US5-B5-R38, US5-B10-R38, US5-B5-T42, US5-B10-T42,

US7-B5-R38, US7-B10-R38, US7-B5-T42, US7-B10-T42,



SCAN to download

This guide provides basic installation information for specific UniStream® models with built-in I/O. Technical specifications may be downloaded from the Unitronics website.

#### **General Features**

Unitronics' UniStream<sup>®</sup> Built-in series are PLC+HMI All-in-One programmable controllers that comprise a built-in CPU, an HMI panel, and built-in I/Os.

The series is available in two versions: UniStream 5" & UniStream 7", and UniStream 5" & UniStream 7" Pro. Note that a model number that includes:

- **B5** refers to UniStream Built-in (e.g. US5-B5-R38/ US7-B5-R38)
- B10 refers to UniStream Built-in Pro (e.g. US5-B10-R38/ US7-B10-R38)
   B10 models offer additional features, detailed below.

<ul><li>Resistive Color Touch-screens</li><li>Rich graphic library for HMI design</li></ul>				
<ul> <li>Built-in Trends and Gauges, auto-tuned PID, data tables, data sampling, and Recipes</li> <li>UniApps™: Access &amp; edit data, monitor, troubleshoot &amp; debug and more – via HMI or remotely via VNC</li> <li>Security: Multi-level password protection</li> <li>Alarms: Built-in system, ANSI/ISA standards</li> </ul>				
<ul> <li>Built-in I/O configuration, varies according to model</li> <li>Local I/O via UAG-CX series I/O expansion adapters and standard UniStream Uni-I/O™ modules</li> <li>Remote I/O via EX-RC1</li> </ul>				
<ul> <li>Built-in ports: 1 Ethernet, 1 USB host, 1 Mini-B USB device port</li> <li>Serial and CANbus ports may be added via UAC-CX modules</li> </ul>				
<ul> <li>Fieldbus: CANopen, CAN Layer2, MODBUS, EtherNetIP and more. Implement any serial RS232/485, TCP/IP, or CANbus third-party protocols via Message Composer</li> <li>Advanced: SNMP Agent/Trap, e-mail, SMS, modems, GPRS/GSM, VNC Client, FTP Server/Client</li> </ul>				
All-in-One software for hardware configuration, communications, and HMI /PLC applications, available as a free download from Unitronics.				
Feature System Memory Audio Jack Video/RSTP Support Web Server	B5 3GB No No	B10 (Pro) 6GB Yes Yes Yes		
	<ul> <li>Rich graphic library for</li> <li>Built-in Trends and Gasampling, and Recipes</li> <li>UniApps™: Access &amp; edmore - via HMI or rem</li> <li>Security: Multi-level pa</li> <li>Alarms: Built-in system</li> <li>Built-in I/O configuration</li> <li>Local I/O via UAG-CX suniStream Uni-I/O™ m</li> <li>Remote I/O via EX-RC</li> <li>Built-in ports: 1 Etherm</li> <li>Serial and CANbus port</li> <li>Fieldbus: CANopen, CA Implement any serial Farotocols via Message</li> <li>Advanced: SNMP Agent VNC Client, FTP Server</li> <li>All-in-One software for hat HMI /PLC applications, av</li> <li>Feature</li> <li>System Memory</li> <li>Audio Jack</li> <li>Video/RSTP Support</li> </ul>	<ul> <li>Rich graphic library for HMI design</li> <li>Built-in Trends and Gauges, auto-tune sampling, and Recipes</li> <li>UniApps™: Access &amp; edit data, monitor more – via HMI or remotely via VNC</li> <li>Security: Multi-level password protect</li> <li>Alarms: Built-in system, ANSI/ISA state</li> <li>Built-in I/O configuration, varies acco</li> <li>Local I/O via UAG-CX series I/O expanding tream Uni-I/O™ modules</li> <li>Remote I/O via EX-RC1</li> <li>Built-in ports: 1 Ethernet, 1 USB host</li> <li>Serial and CANbus ports may be added</li> <li>Fieldbus: CANopen, CAN Layer2, MOD Implement any serial RS232/485, TCI protocols via Message Composer</li> <li>Advanced: SNMP Agent/Trap, e-mail, VNC Client, FTP Server/Client</li> <li>All-in-One software for hardware configuration of the protocols of t</li></ul>		

# **Before You Begin**

Before installing the device, the user must:

- Read and understand this document.
- Verify the Kit Contents.

# **Alert Symbols and General Restrictions**

When any of the following symbols appear, read the associated information carefully.

Symbol	Meaning	Description
<b></b>	Danger	The identified danger causes physical and property damage.
<u>^</u>	Warning	The identified danger could cause physical and property damage.
Caution	Caution	Use caution.

- All examples and diagrams are intended to aid understanding, and do not guarantee operation. Unitronics accepts no responsibility for actual use of this product based on these examples.
- Please dispose of this product according to local and national standards and regulations.
- This product should be installed only by qualified personnel.



- Failure to comply with appropriate safety guidelines can cause severe injury or property damage.
- Do not attempt to use this device with parameters that exceed permissible levels.
- Do not connect/disconnect the device when power is on.

#### **Environmental Considerations**




- Ventilation: 10mm space is required between the device top/bottom edges and the enclosure's walls
- Do not install in areas with: excessive or conductive dust, corrosive or flammable gas, moisture or rain, excessive heat, regular impact shocks or excessive vibration, in accordance with the standards and limitations given in the product's technical specification sheet.
- Do not place in water or let water leak onto the unit.
- Do not allow debris to fall inside the unit during installation.
- Install at maximum distance from high-voltage cables and power equipment.

# **Kit Contents**

- 1 PLC+HMI controller
- 4 mounting brackets
- 1 panel mounting seal
- 2 panel supports (UniStream 7"only)
- 1 power terminal block
- 3 I/O terminal blocks
- 1 Battery

# **Product Diagram**



#### Front and Rear View

1	Screen Protection	A plastic sheet attached to the screen for protection. Remove it during installation of the HMI Panel.		
2	Battery Cover	The battery is supplied with the unit, but must be installed by the user.		
3	Power Supply Input	Connection point for the controller power source.  Connect the Terminal Block supplied with the kit to the end of the power cable.		
4	microSD Slot	Supports standard microSD cards.		
5	USB Host port	Provides the interface for external USB devices.		
6	Ethernet port	Supports high-speed Ethernet communications.		
7	USB Device	Use for application download and direct PC-UniStream communication.		
8	I/O Expansion Jack	Connection point for an I/O Expansion Port.  Ports are supplied as part of I/O Expansion Model Kits. Kits are available by separate order.  Note that UniStream® Built-in is compatible only with adapters from the series UAG-CX.		
9	Audio Jack	Pro models only. This 3.5mm Audio jack enables you to connect external audio equipment.		
10	Built-in I/O	Model-dependent. Present in models with built-in I/O configurations.		
11	Uni-COM™ CX Module Jack	Connection point for up to 3 stack-on modules. These are available by separate order.		


# **Installation Space Considerations**

Allocate space for:


- the controller
- any modules that will be installed
- access to ports, jacks, and the microSD card slot

For exact dimensions, please refer to the Mechanical Dimensions shown below.

#### **Mechanical Dimensions**



#### UniStream 7"



NOTE Allow space for modules to be snapped onto the back of the controller, if required by your application. Modules are available by separate order.


# **Panel Mounting**


NOTE • Mounting panel thickness must be less or equal to 5mm (0.2").

- Ensure that the space considerations are met.
- 1. Prepare a panel cut-out according to the dimensions as shown in the previous section.
- 2. Slide the controller into the cut-out, ensuring that the Panel Mounting Seal is in place as shown below.
- 3. Push the mounting brackets into their slots on the sides of the panel as shown below.
- 4. Tighten the bracket screws against the panel. Hold the brackets securely against the unit while tightening the screws.


When properly mounted, the panel is squarely situated in the panel cut-out as shown below.








UniStream 7"





Caution ■ The necessary torque is 0.35 N·m (3.5 kgf·cm).

# Battery: Back-up, First Use, Installation, and Replacement


# Back-up

In order to preserve back-up values for RTC and system data in the event of power off, the battery must be connected.

#### First Use

The battery is protected by a removable cover on the side of the controller.

The battery is supplied installed inside the unit, with a plastic tab preventing contact which must be removed by the user.




# **Battery Installation and Replacement**



 Use proper precautions to prevent Electro-Static Discharge (ESD) while servicing the battery.

- Caution To preserve back-up values for RTC and system data during battery replacement, the controller must be powered.
  - Note that disconnecting the battery halts the preservation of back-up values and causes them to be deleted.
- 1. Remove the battery cover from the controller as shown in the accompanying figure:
  - Press the tab on the module to disengage it.
  - Slide it up to remove it.
- 2. If you are replacing the battery, remove the battery from its slot on the side of the controller.
- 3. Insert the battery, ensuring that the polarity is aligned with the polarity marking as shown in the accompanying figure.
- 4. Replace the battery cover.
- 5. Dispose of the used battery according to local and national standards and regulations.



# Wiring



- This equipment is designed to operate only at SELV/PELV/Class 2/Limited Power environments.
- All power supplies in the system must include double insulation. Power supply outputs must be rated as SELV/PELV/Class 2/Limited Power.
- Do not connect either the 'Neutral' or 'Line' signal of the 110/220VAC to device's 0V point.
- Do not touch live wires.
- All wiring activities should be performed while power is OFF.
- Use over-current protection, such as a fuse or circuit breaker, to avoid excessive currents into the power supply connection point.
- Unused points should not be connected (unless otherwise specified). Ignoring this directive may damage the device.
- Double-check all wiring before turning on the power supply.

- Caution To avoid damaging the wire, use a maximum torque of 0.5 N·m (5 kgf·cm).
  - Do not use tin, solder, or any substance on stripped wire that might cause the wire strand to break.
  - Install at maximum distance from high-voltage cables and power equipment.

# Wiring Procedure

Use crimp terminals for wiring.

For US5-Bx-T42, US7-Bx-T42 outputs terminal-block use 28-16 AWG wire (0.08 mm<sup>2</sup> -1.3 mm<sup>2</sup>);

For all other terminal blocks, use 26-12 AWG wire (0.13 mm<sup>2</sup> -3.31 mm<sup>2</sup>)

- 1. Strip the wire to a length of  $7\pm0.5$ mm (0.250–0.300 inches).
- 2. Unscrew the terminal to its widest position before inserting a wire.
- 3. Insert the wire completely into the terminal to ensure a proper connection.
- 4. Tighten enough to keep the wire from pulling free.

### Wiring Guidelines

In order to ensure that the device will operate properly and to avoid electromagnetic interference:

- Use a metal cabinet. Make sure the cabinet and its doors are properly earthed.
- Use wires that are properly sized for the load.
- Use shielded twisted pair cables for wiring High Speed and Analog I/O signals. In either case, do not use the cable shield as a signal common / return path.
- Route each I/O signal with its own dedicated common wire. Connect common wires at their respective common (CM) points at the controller.
- Individually connect each 0V point and each common (CM) point in the system to the power supply 0V terminal, unless otherwise specified.
- Individually connect each functional ground point (
   ) to the earth of the system (preferably to the metal cabinet chassis). Use the shortest and thickest wires possible: less than 1m (3.3') in length, minimum thickness 14 AWG (2 mm<sup>2</sup>).
- Connect the power supply 0V to the earth of the system.

- Earthing the cables' shield:
  - Connect the cable shield to the earth of the system (preferably to the metal cabinet chassis). Note that the shield must be connected only at one end of the cable; it is recommended to earth the shield at the PLC-side.
  - Keep shield connections as short as possible.
  - Ensure shield continuity when extending shielded cables.

**NOTE** For detailed information, refer to the document System Wiring Guidelines, located in the Technical Library in the Unitronics' website.


#### Wiring the Power Supply

The controller requires an external power supply.



 In the event of voltage fluctuations or non-conformity to voltage power supply specifications, connect the device to a regulated power supply.

Connect the +V and 0V terminals as shown in the accompanying figure.



# **Connecting Ports**

Ethernet CAT-5e shielded cable with RJ45 connector

USB Device
 Use the proprietary programming cable supplied with the device

USB Host Standard USB cable with Type-A plug

# **Connecting Audio**

Audio-Out

### Audio Pinout

- 1 Headphone Left Out (Tip)
- 2 Headphone Right Out (Ring)



4 Don't connect (Sleeve)



Note that below, the letter "x" that is used in the model numbers means that the section refers both to B5 and B10 models.

#### **I/O Connection Points**

The IOs for these models are arranged in three groups of fifteen points each, as shown in the figures to the right.

# Top groups


Input connection points

#### **Bottom group**


Output connection points

The function of certain I/Os may be adapted via wiring and software settings.

US5-Bx-R38, US7-Bx-R38



US5-Bx-T42, US7-Bx-T42



# **Wiring the Digital Inputs**

The digital inputs are arranged in two isolated groups:

- I0-I9 share common CM0
- I10-I23 share common CM1

Each group may be wired together as sink or source.

Inputs I10-I17 can be configured as either normal digital inputs or as high speed inputs that can receive high speed pulse signals from sensors or shaft encoders.


# **High Speed Input Modes**

Following are the different pin assignments for the high speed channels:

	Channel 1		Channel 2	
	I10	I11	I12	I13
Quadrature	Phase A	Phase B	Phase A	Phase B
Pulse+Direction	Pulse	Direction	Pulse	Direction
Pulse	Pulse	Normal digital	Pulse	Normal digital

	Channel 3		Channel 4	
	I14	I15	I16	I17
Quadrature	Phase A	Phase B	Phase A	Phase B
Pulse+Direction	Pulse	Direction	Pulse	Direction
Pulse	Pulse	Normal digital	Pulse	Normal digital

**NOTE** • Input modes are set both by wiring and software.



NOTE Use sink input wiring to connect a sourcing (pnp) device.

Use source input wiring to connect a sinking (npn) device.

# **Wiring the Analog Inputs**


Both inputs share the common point CM1.

#### NOTE


- The inputs are not isolated.
- Each input offers two modes: voltage or current. You can set each input independently.
- The mode is determined by the hardware configuration within the software application.
- Note that if, for example, you wire the input to current, you must also set it to current in the software application.

#### Voltage

# Differential




Single-ended




#### Current

2-wire




3-wire



12

#### 4-wire




# Wiring the Relay Outputs (US5-Bx-R38, US7-Bx-R38)

<u>/!\</u>

 To avoid risk of fire or property damage, always use a limited current source or connect a current limiting device in series with the relay contacts

The relay outputs are arranged in two isolated groups:

O0-O5 share the common return CM3.
O6-O11 share the common return CM4.



#### **Increasing Contact Life Span**

To increase the life span of the relay contacts and protect the controller from potential damage by reverse EMF, connect:

- a clamping diode in parallel with each inductive DC load,
- a RC snubber circuit in parallel with each inductive AC load



# Wiring the Source Transistor Outputs (US5-Bx-T42, US7-Bx-T42)


#### Output's power supply

The use of any of the outputs requires an external 24VDC power supply as shown in the accompanying figure.

#### **Outputs**

Connect the +VO and 0VO terminals as shown in the accompanying figure.

00-015 share common return 0VO.



### Installing Uni-I/O™ & Uni-COM™ Modules

Refer to the Installation Guides provided with these modules.



- Turn off system power before connecting or disconnecting any modules or devices.
- Use proper precautions to prevent Electro-Static Discharge (ESD).

# **Uninstalling the Controller**

- 1. Disconnect the power supply.
- Remove all wiring and disconnect any installed devices according to the device's installation guide.
- 3. Unscrew and remove the mounting brackets, taking care to support the device to prevent it from falling during this procedure.

The information in this document reflects products at the date of printing. Unitronics reserves the right, subject to all applicable laws, at any time, at its sole discretion, and without notice, to discontinue or change the features, designs, materials and other specifications of its products, and to either permanently or temporarily withdraw any of the forgoing from the market.

All information in this document is provided "as is" without warranty of any kind, either expressed or implied, including but not limited to any implied warranties of merchantability, fitness for a particular purpose, or non-infringement. Unitronics assumes no responsibility for errors or omissions in the information presented in this document. In no event shall Unitronics be liable for any special, incidental, indirect or consequential damages of any kind, or any damages whatsoever arising out of or in connection with the use or performance of this information.

The tradenames, trademarks, logos and service marks presented in this document, including their design, are the property of Unitronics (1989) (R"G) Ltd. or other third parties and you are not permitted to use them without the prior written consent of Unitronics or such third party as may own them

DOC30003-B6 07/18